



OIL WATER SEPARATOR INSPECTION LOG

Directions: Facility must inspect oil water separated at a **minimum of every 90 days** and record results. If free oil has accumulated on surface it must be removed. Regardless of inspection, the separator must be pumped out at a minimum frequency of once every 180 days (6 months). **Maintain log for minimum three years from last record.**

FACILITY NAME:

ADDRESS:

DATE	SURFACE OF SEPARATOR OBSERVATION			SEPARATOR PUMPED OUT?		NAME OF INSPECTOR (PRINT)	SIGNATURE OF INSPECTOR
				Yes	No		
	Choose one:						
	No visible oil	Sheen	Free oil				



REGISTRO DE INSPECCIONES DEL SEPARADOR DE ACEITE AGUA

Instrucciones: Los talleres deben inspeccionar el aceite y agua separados como **mínimo cada 90 días** y registrar los resultados. Si hay una acumulación de aceite en la superficie, ésta debe ser quitada. Sin importar la inspección, el separador debe ser bombeado como mínimo una vez cada 180 días (6 meses). **Mantenga el registro por un período mínimo de tres años del último registro.**

NOMBRE DEL TALLER:

DOMICILIO:

FECHA	¿QUÉ OBSERVÓ EN LA SUPERFICIE DEL SEPARADOR			¿FUE BOMBEADO EL SEPARADOR?		NOMBRE DEL INSPECTOR (EN LETRA DE MOLDE)	FIRMA DEL INSPECTOR
	Seleccione uno:			Sí	No		
	No hubo aceite visible	Brillante	Sin aceite				